

# MAXIMUM REACH ENTERPRISES

1853 Wellington Court  
Henderson, NV 89014  
Ph: 702 547 1564  
kent.goodman @ cox.net  
[www.maximumreach.com](http://www.maximumreach.com)

01 June 2012

## THE MILLSTONE II STEAM GENERATOR REPLACEMENT PROJECT WATERFORD, CONNECTICUT

### — Millstone Nuclear — Power Station




**Unit 2 is the tall building just to the right of the stack**











## DESIGN OF THE STINGER BEAM FOR THE TAILING ASSEMBLY

### COMMENTS:

1. The 7 sheet check list is not included.
2. Presentation page 5 shows the calculation cover & signature sheet for the calculations.
3. Presentation page 6 shows the first sheet of 47 sheets of the actual calculations of the stinger beam.
4. These design calculations were listed as SC-048 on our design calculation log.
5. The 46' length of the stinger beam was determined by the dimensions of the 600 ton transporter, the closest that the fulcrum stand could be located to the equipment hatch and the reach needed to position the flange lug under the centerline of the SGLA when it was as close to the containment wall as the H6 hoist could trolley it, ie, 11' – 6". See calculation sheet 2.
6. Design references such as the AISC manual have not been included. If anyone wants to have any of the formulas explained, just let me know.
7. Presentation page 2 shows an overall drawing of the tailing assembly just to show how all of the components fit together.

8. Presentation page 3 shows the detail drawing of the stinger beam to give the reader an overall view of the design before going into the calculations.
9. To enlarge the drawing for better viewing, click on the **view** tab and change it to say 200 %.
10. Presentation page 4 contains the detail drawing of the counterweight carrier frame & the 600 ton transporter so the reader can see where a lot of the dimensions came from in the stinger beam design and how it connects to the stinger beam to form the tailing assembly.





- NOTES:**
1. ALL MATERIALS SHALL BE ASTM A36 (F<sub>y</sub> 100KSI) UNLESS NOTED OTHERWISE.
  2. ALL PIPE & SHAPES SHALL BE MATL. 4140 (F<sub>y</sub> 100KSI).
  3. FOR GENERAL NOTES SEE DWG. 80242-89300. SEE SPEC. 81000-81010 FOR THE STRUCTURAL STEEL FOR TEMPORARY CONSTRUCTION.
  4. PERMANENT PROTECTION NOT APPLICABLE TO THIS. (SEE SECTION 18, 1972. COA. OPERATION BY THE CONTRACTOR)
  5. STEEL SHALL BE PRIMED IN ACCORDANCE WITH SPECIFICATION. USE OIL-BASED TOP COAT. SLURRY COAT WITH ONE COAT OF PRIMER. PRIMER COMPATIBLE WITH THE PRIMER USED.

**INFORMATION COPY**

**FLUOR DANIEL**

**NORTHEAST UTILITIES SERVICE CO.**  
100 MILLSTONE TOWER POWER STATION  
UNIT NO. 1

**STINGER BEAM DETAILS**

PROJECT NO. 86242-89300  
DATE: 11/11/82  
DRAWN BY: [Signature]  
CHECKED BY: [Signature]  
SCALE: AS SHOWN  
NO. 86242-59377

**REVIEWED**  
AUG 28 1992  
**DOCUMENT CONTROL**

NO.	DESCRIPTION	DATE	BY	CHECKED





**FLUOR DANIEL**

CALCULATION COVER SHEET

PROJECT: **NUSCO-MILLSTONE 2**  
NUCLEAR POWER STATION  
CLIENT: **S/G REPLACEMENT PROJECT**  
PROJECT NO:

ASSIGNMENT INFORMATION	
Dept. Name	<u>STRUCTURAL</u>
System No.	<u>SGR</u>
Calc. No.	<u>SC-048</u> Work Item <u>—</u>
Revision	<u>0</u> Date <u>1 JULY 91</u>

Title: STINGER BEAM FOR STEAM GENERATOR  
REMOVAL & INSTALLATION (HEME 3)

Content: 7 PAGE CHECK LIST N/A  
47 PAGES OF CALCULATIONS & SKETCHES

NSR:  YES  NO

Designed/Calculated By:

Checked By:

Approved and Released By:

Professional Engineer's Seal No.

Reviewed BY:

QA Review:


Distribution:

Original to Project File

Copies To:

NAME	INITIAL	DATE
<u>KENT GOODMAN</u>	<u>KEG</u>	<u>1 JULY 91</u>
<u>[Signature]</u>	<u>EDB</u>	<u>Sept. 3 '91</u>
<u>[Signature]</u>	<u>RJB</u>	<u>OCT 1, 91</u>

State of ET.



NOTE: This form must be legible and suitable for microfilming.

**NUSCO-MILLSTONE 2  
NUCLEAR POWER STATION  
S/G REPLACEMENT PROJECT**

10	C <sub>1</sub>	6.46
20	C <sub>2</sub>	9.57
34	C <sub>1</sub>	18.24
50	IC <sub>1</sub>	12.00
60	C <sub>1</sub>	11.95
77	IC <sub>1</sub>	19.88
77	C <sub>1</sub>	19.74
86	IC <sub>1</sub>	15.8
86	C <sub>1</sub>	15.99
100	IC <sub>1</sub>	17.2
100	C <sub>1</sub>	17.00
114	C <sub>1</sub>	19.41
25	C <sub>1</sub>	9.84
42	C <sub>1</sub>	9.87

1	W <sub>1</sub>	3.50
2	W <sub>2</sub>	4.18
3	W <sub>3</sub>	5.18
4	W <sub>4</sub>	6.47

1. PURPOSE & SCOPE

THE PURPOSE OF THIS SET OF CALCULATIONS IS TO DESIGN THE STINGER BEAM & PIN FOR USE IN DOWN/UP ENDING THE SGLA'S

2. REFERENCES & DESIGN INPUT

- A. ANSI/ASME N45.2.15 1981 NUCLEAR RIGGING
- B. ASME B30.5 1989 MOBILE & LOCOMOTIVE CRANES
- C. AISC MANUAL FOR STEEL CONSTRUCTION 9TH ED
- D. THE CROSBY PRODUCTS GENERAL CATALOG
- E. FLUOR RIGGING DESIGN MANUAL
- F. MACWHYTE CATALOG OF TABLES, ETC 6-17, 11TH ED
- G. DESIGN OF WELDED STRUCTURES 7TH ED

3. SUMMARY OF RESULTS & CONCLUSIONS


THE STINGER CAN BE DESIGNED & FABRICATED TO SAFELY DOWN/UP END THE SGLA BY ADHERING TO THE DESIGN CODES & STANDARDS LISTED ABOVE.

4. CRITERIA & ASSUMPTIONS

- A. SAFE WORKING LOAD (SWL) FOR DESIGN OF COMMERCIAL RIGGING GEAR = 5:1 SF.
- B. DUE TO THE CRITICAL APPLICATION, THE STINGER IMPACT FACTOR = 1.5
- C. USE 0.5F<sub>y</sub> FOR BEARING (NO IMPACT)
- D. USE HOLE  $\phi$  1/8" OVER PIN  $\phi$

NUSCO-MILLSTONE 2  
NUCLEAR POWER STATION  
B/G REPLACEMENT PROJECT

SC-048  
FLUOR  
DATE 9 July 91  
CALCULATIONS and SKETCHES  
CONF. NO. 820100  
BY [Signature]  
SHEET NO. 2




SC-048

**NUSCO-MILLSTONE 2**  
**NUCLEAR POWER STATION**  
**S/G REPLACEMENT PROJECT**

NO	gas/mol
16	C <sub>1</sub> 8.09
36	C <sub>2</sub> 9.87
64	C <sub>3</sub> 16.94
86	HC <sub>4</sub> 12.48
88	C <sub>5</sub> 11.95
72	HC <sub>6</sub> 13.28
72	C <sub>7</sub> 13.74
86	HC <sub>8</sub> 14.1
86	C <sub>9</sub> 15.56
100	HC <sub>10</sub> 17.2
114	C <sub>11</sub> 19.01
28	C <sub>12</sub> 9.84
42	C <sub>13</sub> 9.87

**STINGER BEAM DESIGN**

NOTE:  
 ALL HORIZONTAL  
 DIMENSIONS & TRANSPORTER  
 WILL BE REF.  
 FROM THE &  
 TRANSPORTER  
 I.E. THE  
 MOMENT AT  
 THE FULCRUM  
 STAND WOULD  
 BE DESIGNATED  
 M<sub>20'</sub>



$\sum M_{R_1} \uparrow = 0$

$20 R_2 = 23.0' * 100k + 46' * 286k$

$R_2 = 772.8 k$

$\therefore R_1 = 386.8 k$

NO	gas/mol
64	CO <sub>2</sub> 6.47
34	H <sub>2</sub> 5.18
28	H <sub>2</sub> 4.18
2	H <sub>2</sub> 1.38

\* ASSUMED


**NUSCO-MILLSTONE 2**  
 NUCLEAR POWER STATION  
 STG REPLACEMENT PROJECT

NO	DATE/REV
16	C, 8.00
20	C, 9.07
44	C, 10.44
60	HC, 12.00
68	C, 11.96
77	HC, 13.00
77	HC, 13.74
67	HC, 15.13
74	C, 15.67
100	HC, 17.12
100	C, 17.40
114	C, 19.41
128	C, 20.54
42	C, 20.87

DETERMINE THE VERTICAL TRAVEL  
 DISTANCE FOR THE  
 STINGER TIP


$$H_{MAX} = 13.75/2 + 1.5' + .5'$$

$$= 8.875'$$



$$H_{MIN} = 7''$$

USE 5''




$$\therefore \text{MAX TRAVEL} = 8.875' - .42' = 8.46'$$

\* PER FDC  
 CAD DWG

NO	DATE/REV
44	CO, 8.47
34	H, 5.18
26	H, 4.18
2	H, 3.28

1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	32	33	34	35	36
---	---	---	---	---	---	---	---	---	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----

1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	32	33	34	35	36
---	---	---	---	---	---	---	---	---	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----



NUSCO-MILLSTONE 2  
NUCLEAR POWER STATION  
S/G REPLACEMENT PROJECT

FLUOR DANIEL  
SC-048  
CALCULATIONS AND SKETCHES

DATE 9 July 91  
CONT. NO. 830100  
BY A. GOODMAN  
SHEET NO. 5

SC-048

FLUOR DANIEL



CALCULATIONS and SKETCHES

DATE 9 July 91

CONT. NO. 830100

BY KE600DMA/CHK'D


SHEET NO. 6

**NUSCO-MILLSTONE 2  
NUCLEAR POWER STATION  
S/G REPLACEMENT PROJECT**

REV	DATE	BY
16	C <sub>1</sub>	6.40
18	C <sub>2</sub>	9.87
24	C <sub>3</sub>	18.44
26	IC <sub>1</sub>	12.00
28	C <sub>4</sub>	11.98
72	IC <sub>2</sub>	13.88
74	C <sub>5</sub>	13.74
80	IC <sub>3</sub>	16.3
82	C <sub>6</sub>	18.68
100	IC <sub>4</sub>	17.2
102	C <sub>7</sub>	17.69
114	C <sub>8</sub>	18.41
120	C <sub>9</sub>	9.80
122	C <sub>10</sub>	9.87

MSC	DATE	BY
14	CD <sub>1</sub>	6.47
14	H <sub>1</sub>	5.18
18	H <sub>2</sub>	4.18
2	H <sub>3</sub>	3.38

FORM E-050  
PRINTED IN U.S.A.




$$\theta = 6.04^\circ + 13.64^\circ = 19.68^\circ$$

$$y = 17.1'$$

$$x = 43.31'$$

$$z = 2.1'$$


ANGLES & DIMENSIONS WHEN THE STINGER IS INCLINED AT 19.68°



**NUSCO-MILLSTONE 2**  
**NUCLEAR POWER STATION**  
**S/G REPLACEMENT PROJECT**

MW	gas/mol
16	C <sub>2</sub> 6.40
30	C <sub>2</sub> 9.87
44	C <sub>2</sub> 13.44
58	HC <sub>2</sub> 17.00
72	C <sub>2</sub> 11.96
77	HC <sub>2</sub> 13.88
72	C <sub>2</sub> 13.74
67	HC <sub>2</sub> 15.5
56	C <sub>2</sub> 15.69
100	HC <sub>2</sub> 17.2
100	C <sub>2</sub> 17.40
116	C <sub>2</sub> 18.41
28	C <sub>2</sub> 9.54
47	C <sub>2</sub> 9.87

SOLVE FOR THE FORCES IN THE STINGER BEAM (HORIZONTAL)



$$\sum M_a = 0$$

$$-20'R_2 + 23' \times 100k + 46' \times 286k = 0$$

$$20R_2 = 15,456 \text{ k-ft}$$

$$R_2 = 772.8 \text{ k}$$

$$R_3 = 0$$

$$R_1 = 386.8 \text{ k}$$

MSC	gas/mol
44	CO <sub>2</sub> 6.47
34	H <sub>2</sub> 5.18
28	H <sub>2</sub> 4.16
7	H <sub>2</sub> 3.56

CALCULATIONS and SKETCHES


**NUSCO-MILLSTONE 2**  
**NUCLEAR POWER STATION**  
**STG REPLACEMENT PROJECT**

HW	gals/mi
16	C <sub>1</sub> 8.40
30	C <sub>2</sub> 9.87
44	C <sub>3</sub> 10.44
58	IC <sub>4</sub> 12.40
72	C <sub>5</sub> 11.90
86	IC <sub>6</sub> 13.80
100	C <sub>7</sub> 13.74
114	IC <sub>8</sub> 15.5
128	C <sub>9</sub> 15.60
142	IC <sub>10</sub> 17.2
156	C <sub>11</sub> 17.40
170	C <sub>12</sub> 19.41
184	C <sub>13</sub> 19.64
198	C <sub>14</sub> 19.87

MSC	gals/mi
44	CO <sub>2</sub> 8.47
54	H <sub>2</sub> 8.18
64	H <sub>2</sub> 4.16
74	H <sub>2</sub> 3.38

FORM E-050  
 PRINTED IN U.S.A.


**SHEAR & MOMENT DIAGRAMS**  
**(WITH STINGER LEVEL)**



**NUSCO-MILLSTONE 2**  
 NUCLEAR POWER STATION  
 S/G REPLACEMENT PROJECT

HW	gals/min
18	C <sub>1</sub> 6.40
30	C <sub>2</sub> 9.67
44	C <sub>3</sub> 10.44
50	IC <sub>1</sub> 12.40
58	C <sub>4</sub> 11.90
72	IC <sub>2</sub> 13.80
77	C <sub>5</sub> 13.74
86	IC <sub>3</sub> 15.5
94	C <sub>6</sub> 15.90
100	IC <sub>4</sub> 17.2
100	C <sub>7</sub> 17.40
114	C <sub>8</sub> 18.41
128	C <sub>9</sub> 18.64
142	C <sub>10</sub> 18.87

MSC	gals/min
1	CO <sub>2</sub> 8.47
1	H <sub>2</sub> 3.10
1	H <sub>2</sub> 4.16
2	H <sub>2</sub> 3.30



STINGER TIP AT LOW POINT

$$\theta = 19.68^\circ$$

$$\alpha = 8.15^\circ$$

$$\beta = 24.79^\circ$$

POINT "a" IS AT THE INTERSECTION OF  
 $R_1$  &  $R_3$

**NUSCO-MILLSTONE 2**  
**NUCLEAR POWER STATION**  
**57G REPLACEMENT PROJECT**

16	C <sub>1</sub>	6.46
20	C <sub>2</sub>	9.87
24	C <sub>3</sub>	18.44
28	C <sub>4</sub>	22.96
32	C <sub>5</sub>	11.96
36	C <sub>6</sub>	13.86
40	C <sub>7</sub>	13.74
44	C <sub>8</sub>	16.8
48	C <sub>9</sub>	15.97
52	C <sub>10</sub>	17.7
56	C <sub>11</sub>	17.99
60	C <sub>12</sub>	18.41
64	C <sub>13</sub>	8.84
68	C <sub>14</sub>	9.87

SOLVE FOR  $R_1$ ,  $R_2$  &  $R_3$

WHEN  $\theta = 19.68^\circ$

$\sum M_a \uparrow = 0$

$$-(20' - 1.49') \times R_2 \cos \theta - (9.39' - 2.75') \times R_2 \sin \theta$$

$$+ (46' - 1.49') \times 269.3k + 9.39' \times 96.3k$$

$$+ (23.0' - 1.49') \times 94.2k + 9.39' \times 33.7k = 0$$

$$19.67 R_2 = 15,009.3$$

$$R_2 = 763.1k$$

$\sum F_y \uparrow = 0$

(1)  $-R_1 \cos \beta + R_3 \sin \alpha + R_2 \cos \theta - 94.2 - 264.6 = 0$

$$-.99 R_1 + .42 R_3 = -359.7k$$

$\sum F_x \rightarrow = 0$

(2)  $R_1 \sin \beta + R_3 \cos \alpha - R_2 \sin \theta + 33.7k + 94.7k = 0$

$$.14 R_1 + .91 R_3 = 128.6k$$

MULTIPLY

(2) by 7.07

& Add To

(1)  $.99 R_1 + 6.44 R_3 = 909.4k$

(2)  $.14 R_1 + .91 R_3 = 128.6k$

$$R_3 = 80.1k$$

$$R_1 = 397.7k$$


16	CO <sub>1</sub>	6.47
24	H <sub>1</sub>	6.18
32	H <sub>2</sub>	4.16
40	H <sub>3</sub>	6.38

**NUSCO-MILLSTONE 2**  
**NUCLEAR POWER STATION**  
**STG REPLACEMENT PROJECT**

HW	gas/mol
16	C <sub>1</sub> 8.08
20	C <sub>2</sub> 9.87
44	C <sub>3</sub> 18.44
58	HC <sub>4</sub> 12.00
58	C <sub>4</sub> 11.95
72	HC <sub>5</sub> 13.88
72	C <sub>5</sub> 13.74
86	HC <sub>6</sub> 15.5
86	C <sub>6</sub> 15.39
100	HC <sub>7</sub> 17.2
100	C <sub>7</sub> 17.00
114	C <sub>8</sub> 18.41
128	C <sub>9</sub> 19.84
142	C <sub>10</sub> 21.27

MSC	
HW	gas/mol
14	CO <sub>2</sub> 8.47
34	H <sub>2</sub> 5.18
38	H <sub>2</sub> 4.18
7	H <sub>2</sub> 3.38

FORM E-050  
 PRINTED IN U.S.A.



**NUSCO-MILLSTONE 2**  
**NUCLEAR POWER STATION**  
**S/G REPLACEMENT PROJECT**

NO	DATE	REVISION
16	C	6.40
30	C	9.87
44	C	10.04
58	IC	12.00
66	C	11.98
77	IC	13.88
72	C	13.74
86	IC	15.5
86	C	15.50
100	IC	17.2
100	C	17.00
114	C	19.01
26	C	8.64
42	C	9.87

NO	DATE	REVISION
M	CO	6.07
M	H	5.18
M	H	4.18
Z	H	3.30

FORM E-050  
 PRINTED IN U.S.A.

1  
 2 **SIZE THE STINGER BEAM**  
 3 SECTION AT 20' FROM  $\phi$  TRANSPORTER  
 4 MAX. MOMENT OCCURS AT  
 5  $\phi$  OF THE FULCRUM STAND (REF SH 12)

6  
 7  $= 7869 \text{ k-ft} = 94,428 \text{ k-in}$

8  
 9 USE 1.5 FOR IMPACT  
 10 USE A 514  $F_y = 100 \text{ KSI}$  MATL

11  
 12  $\therefore$  DESIGN MOMENT  $= 141,642 \text{ k-in}$

13  
 14 TRY A BOX SECTION WITH  
 15 WEB DEPTH  $\approx 46''$   $t_w = 1\frac{1}{2}''$   
 16 FLANGE WIDTH  $\approx 50$

17  
 18 AISC  $\frac{h}{t_w} = 15.3 < \frac{760}{\sqrt{60}} = 98$   
 19 CHAPTER G

20  
 21  $\therefore$  USE CHAPTER F FOR ALLOW. STRESSES.  
 22  $\rightarrow$  NON-COMPACT SECTION

23  $F_b = .6 F_y = 60.0 \text{ KSI}$   
 24  $F_v = .4 F_y = 40.0 \text{ KSI}$

25  
 26 CHECK SHEAR

27  
 28  $f_v = \frac{763 \text{ k} \times 1.5}{2 \times 1\frac{1}{2}'' \times 46''} = 8.29 \text{ ksi} \quad \text{O.K.}$

29  
 30  
 31 CHECK FOR NEED OF INTER-MEDIATE STIFFENERS

32  
 33 AISC F5  $\frac{h}{t_w} = 15.3 < 260$  NO NEED  
 34  
 35  
 36

**NUSCO-MILLSTONE 2**  
**NUCLEAR POWER STATION**  
**S/G REPLACEMENT PROJECT**

MM	GRA/MI
16	C <sub>1</sub> 8.40
20	C <sub>2</sub> 9.87
24	C <sub>3</sub> 16.54
36	IC <sub>1</sub> 12.40
48	C <sub>4</sub> 11.85
72	IC <sub>2</sub> 13.88
72	C <sub>5</sub> 13.74
84	C <sub>6</sub> 15.59
84	IC <sub>3</sub> 17.2
100	C <sub>7</sub> 19.41
72	C <sub>8</sub> 9.84
42	C <sub>9</sub> 9.87

MSC	GRA/MI
1	CO <sub>2</sub> 8.47
1	H <sub>2</sub> O 5.18
1	H <sub>2</sub> 4.16
2	H <sub>2</sub> 3.38

CHECK FLANGE AREA REQ. (INITIAL TRY)

AISC 2-215

$$A_{(ONE\ FLANGE)} = \frac{M}{F_b \times h} = \frac{141,642 \text{ k-in} \times 10^2}{40.0 \text{ K} \times 46 \text{ in}} = 51 \text{ in}^2$$

∴ TRY FLANGE : 1 1/2" x 52" = 78.0 in<sup>2</sup> O.K.




PLATE SIZE (b x d) in	Y in	A (b x d) in <sup>2</sup>	M (A x Y) in <sup>3</sup>	I <sub>y</sub> M x Y in <sup>4</sup>	I <sub>g</sub> (bd <sup>3</sup> /12) in <sup>4</sup>
A 2 x 46	25	92	2,300	57,500	16,223
B 2 x 46	25	92	2,300	57,500	16,223
C 52 x 2	49	104	5,096	249,704	35
D 52 x 2	1	104	104	104	35
		392	9,800	364,808	32,516

**NUSCO-MILLSTONE 2**  
 NUCLEAR POWER STATION  
 S/G REPLACEMENT PROJECT

NO	DES./REV.
16	C <sub>1</sub> 6.00
20	C <sub>2</sub> 9.07
24	C <sub>3</sub> 10.04
28	C <sub>4</sub> 12.00
32	C <sub>5</sub> 11.90
36	C <sub>6</sub> 13.00
40	C <sub>7</sub> 12.74
44	C <sub>8</sub> 12.8
48	C <sub>9</sub> 12.97
52	C <sub>10</sub> 12.2
56	C <sub>11</sub> 12.00
60	C <sub>12</sub> 12.04
64	C <sub>13</sub> 9.07

1 FROM SH 19

2 
$$I_N = I_y + I_z - M^2/A$$
  
 3 
$$= 270,868 + 25,166 - 7,313^2/295.5 = 115,052 \text{ in}^4$$

4  
 5 NEUT. AXIS CHECK =  $\frac{7313}{295.5} = 25''$  OK

6  
 7 
$$f_b = \frac{141,642 \text{ k-in} \times 25 \text{ in}}{115,073 \text{ in}^4} = 30.8 \text{ ksi OK}$$

8  
 9 
$$f_v = \frac{763 \text{ k} \times 1.5}{2 \times 1\frac{1}{2} \text{ in} \times 46.5 \text{ in} \times \text{in}^2} = 8.2 \text{ ksi OK}$$

10 LOCAL BUCKLING

11 AISC B5.1 § Pg 2-215

12  
 13 
$$\frac{d_f}{2 \times t_f} = \frac{52''}{2 \times 1\frac{1}{2}''} = 17.4 < 238/\sqrt{F_y} = 23.8 \text{ O.K.}$$

14 BEARING STIFFENERS

15 AISC K1.3 WEB YIELDING

16  
 17 
$$R = \frac{763 \times 1.5}{2 \times 1\frac{1}{2} (42 + 5 \times 1.5)} = 8.8 \text{ ksi O.K.}$$

18 SEE SH 36  $\frac{1}{2}''$  FILLET ASSUMED

19 K1.4 a WEB CRIPPLING

20  
 21 
$$R = 67.5 \times 1\frac{1}{2}^2 \left[ 1 + 3 \left( \frac{42}{50} \right)^{1.5} \left( \frac{1\frac{1}{2}}{1\frac{1}{2}} \right)^{1.5} \right] \sqrt{100 \times 1\frac{1}{2} / 1\frac{1}{2}}$$

22  
 23 
$$= 5346 \text{ k} > \frac{763.1 \text{ k} \times 1.5}{2} = 572 \text{ k}$$

24 O.K.

NO	DES./REV.
CO <sub>1</sub>	6.47
H <sub>1</sub>	3.18
H <sub>2</sub>	4.16
H <sub>3</sub>	3.38

**NUSCO-MILLSTONE 2**

**NUCLEAR POWER STATION**

**S/G REPLACEMENT PROJECT**

16	C <sub>1</sub>	4.48
30	C <sub>1</sub>	9.87
44	C <sub>1</sub>	16.44
58	IC <sub>1</sub>	12.46
72	C <sub>1</sub>	11.99
86	IC <sub>1</sub>	13.88
100	C <sub>1</sub>	15.74
114	IC <sub>1</sub>	15.5
128	C <sub>1</sub>	15.99
142	IC <sub>1</sub>	17.2
156	C <sub>1</sub>	17.49
170	C <sub>1</sub>	19.41
184	C <sub>1</sub>	23.4
198	C <sub>1</sub>	28.7

MSC	MSB/MSB
14	CO <sub>2</sub> 6.47
14	H <sub>2</sub> 5.19
28	H <sub>2</sub> 4.16
7	H <sub>2</sub> 3.38

FLANGE TO WEB (FILLET WELD)

HORIZONTAL SHEAR  $v = \frac{VQ}{I}$

$V = \frac{281.0 \text{ k} \times 1.5}{2} = 210.8 \text{ k}$

$Q = 78.0 \text{ in}^2 \times 24 \text{ in} = 1872.0 \text{ in}^3$   
 (FLANGE AREA) ← M. ARM

$v = \frac{210.8 \text{ k} \times 1872.0 \text{ in}^3}{115,073 \text{ in}^4} = 3.4 \text{ k/in}$

WELD SIZE =  $\frac{3.4 \text{ k} \times 1 \text{ in} \times 1 \text{ in}}{1 \text{ in} \times 2 \text{ WELDS} \times 9.6 \text{ k}} = .18 \text{ in}$   
 ← LHGO

∴ USE 3/8" FILLET BOTH SIDES OF THE WEBS

CHECK THE TORSIONAL LOADING DUE TO THE WIRE ROPE FROM SH 26 THE LEAD LINE PULL = 26.3 k

THE DEAD END PULL =  $\frac{393.3 \text{ k}}{24 \text{ PARTS}} = 16.4 \text{ k}$

FROM SH 28 THE DISTANCE FROM  $\phi$  A OUT SIDE SHEAVE TO  $\phi$  STINGER  
 =  $\frac{51.25 \text{ in} - 1 \text{ in} - 1/8 \text{ in} - 3.5 \text{ in}}{2} = 22.75 \text{ in}$

LOAD/SHEAVE AT LEAD LINE SIDE =  
 =  $2 \times 26.3 \text{ COS } B = 52.1 \text{ k}$   
 ← TO GET FORCE  $\perp$  TO STINGER  $\phi$


**NUSCO-MILLSTONE 2**  
**NUCLEAR POWER STATION**  
**S/G REPLACEMENT PROJECT**

NO	QTY	UNIT
16	C <sub>1</sub>	6.40
38	C <sub>1</sub>	9.87
44	C <sub>1</sub>	10.44
58	IC <sub>1</sub>	12.40
66	C <sub>1</sub>	11.94
72	IC <sub>1</sub>	13.88
72	C <sub>1</sub>	13.74
86	IC <sub>1</sub>	15.5
86	C <sub>1</sub>	15.50
100	IC <sub>1</sub>	17.2
100	C <sub>1</sub>	17.40
114	C <sub>1</sub>	18.41
28	C <sub>1</sub>	9.64
42	C <sub>1</sub>	9.87

LOAD/SHEAVE AT DEAD END

$$= 2 \times 16.4k \times \cos B = 32.5k$$

DIFFERENCE IN FORCES = 52.1 - 32.5 = 19.6k



$$P = \frac{19.6k \times 12 \text{ SHEAVES}}{2}$$

$$= 117.6k$$

TORSIONAL MOMENT = 117.6k \* 7.73" = 909.0 in-k

FROM DESIGN OF WELDED STRUCTURES P<sub>2</sub> 2.10-4

$$R = \frac{2 b_1^2 d_1^2}{\frac{b_1}{E_b} + \frac{d_1}{E_d}} = \frac{2 \times 48^2 \text{ in}^2 \times 24^2 \text{ in}^2}{\frac{48 \text{ in}}{112 \text{ in}} + \frac{24 \text{ in}}{112 \text{ in}}} = 55,296 \text{ in}^4$$

at 1.75" FROM CRAWLER TORSIONAL RESIST.

ANGULAR TWIST AT TIP OF STINGER P<sub>2</sub> 8.2-1

$$\theta = \frac{TL}{E_{\text{steel}} R} = \frac{909.0 \text{ in-k} \times 20 \text{ FT} \times 12 \text{ IN} \times \text{IN}^2}{12,000 \text{ K} \times 55,296 \text{ IN}^4 \times \text{FT}} = 0.00033 \text{ RAD}$$

= .01°  
 Low!  
 O.K.

**NUSCO-MILLSTONE 2**  
**NUCLEAR POWER STATION**  
**S/G REPLACEMENT PROJECT**

NO	QTY	UNIT
16	C <sub>1</sub>	6.40
30	C <sub>2</sub>	9.87
44	C <sub>3</sub>	18.44
58	IC <sub>1</sub>	12.00
72	IC <sub>2</sub>	11.95
86	IC <sub>3</sub>	13.88
100	IC <sub>4</sub>	15.3
114	IC <sub>5</sub>	15.99
128	IC <sub>6</sub>	17.2
142	IC <sub>7</sub>	17.49
156	C <sub>4</sub>	19.41
170	C <sub>5</sub>	2.64
184	C <sub>6</sub>	9.87

NO	QTY	UNIT
1	CO <sub>2</sub>	4.47
2	H <sub>2</sub> O	5.18
3	H <sub>2</sub>	4.18
4	H <sub>2</sub>	3.30

FORM E-050  
 PRINTED IN U.S.A.

**TORSIONAL SHEAR STRESS**

$$\tau = \frac{T}{2 A e_w} = \frac{909.0 \text{ in-k}}{2 \times 48'' \times 24'' \times 1/2''} = .26 \text{ ksi}$$

**UNIT SHEAR FORCE FROM TORQUE**

$$f_t = \tau e = \frac{.2 \text{ K} \times 1/2''}{1 \text{ in}^2} = .3 \text{ k/in}$$

$$v \text{ FROM SH 16} = 3.4 \text{ k/in}$$

**TOTAL UNIT SHEAR FORCE (PER BEAM)**

$$= .3 + 3.4 = 3.7 \text{ k/in}$$


**TOTAL SHEAR STRESS**

$$\frac{3.7 \text{ k}}{1 \text{ in} \times 1/2 \text{ in}} = 2.5 \text{ ksi OK}$$

RECHECK THE WELD SIZE AFTER  
 ADDING THE TORQUE STRESS

$$w = \frac{\text{ACTUAL FORCE}}{2 \times \text{ALLOWABLE FORCE}} = \frac{3.7 \text{ K in}}{2 \times 9.6 \text{ k/in}} = 0.19''$$

USE 3/8" WELD SIZE



∴ TORQUE DOESN'T HAVE MUCH  
 EFFECT ON THE DESIGN.

**NUSCO-MILLSTONE 2**  
**NUCLEAR POWER STATION**  
**S/G REPLACEMENT PROJECT**

18	C <sub>1</sub>	6.40
30	C <sub>2</sub>	9.87
42	C <sub>3</sub>	16.44
54	IC <sub>1</sub>	12.40
66	C <sub>4</sub>	11.95
72	IC <sub>2</sub>	13.88
72	C <sub>5</sub>	13.74
84	IC <sub>3</sub>	15.5
96	C <sub>6</sub>	15.59
108	IC <sub>4</sub>	17.2
120	C <sub>7</sub>	17.40
114	C <sub>8</sub>	19.41
36	C <sub>9</sub>	9.84
42	C <sub>10</sub>	9.87

MSC	
W	gms/mil
C	CO <sub>2</sub> 8.47
H	H <sub>2</sub> 5.18
N	N <sub>2</sub> 4.18
H	H <sub>2</sub> 3.34

*TYPE II CROSS SECTION*




PLATE	SIZE (bxd) in	Y in	A (dxd) in <sup>2</sup>	M (A*Y) in <sup>3</sup>	I <sub>y</sub> (M*Y) in <sup>4</sup>	I <sub>x</sub> (bd <sup>3</sup> /12) in <sup>4</sup>
A	1 1/2 x 46.5	24.75	69.75	1,724	42,726	12,568
B	1 1/2 x 46.5	24.75	69.75	1,724	42,726	12,568
C	52 x 1 1/2	48.75	78.00	3,803	185,372	15
D	52 x 1 1/2	.75	78.00	58	44	15
			295.5	7,313	270,868	25,166

NEUTRAL AXIS =  $M/A = 24.75"$

$I_N = 115,052 \text{ in}^4$

**NUSCO-MILLSTONE 2**  
**NUCLEAR POWER STATION**  
**S/G REPLACEMENT PROJECT**

18	C <sub>1</sub>	6.40
19	C <sub>2</sub>	9.87
20	C <sub>3</sub>	10.64
21	HC <sub>1</sub>	12.40
22	C <sub>4</sub>	11.99
23	HC <sub>2</sub>	13.20
24	C <sub>5</sub>	13.74
25	HC <sub>3</sub>	15.9
26	C <sub>6</sub>	15.50
27	HC <sub>4</sub>	17.2
28	C <sub>7</sub>	17.40
29	C <sub>8</sub>	19.41
30	C <sub>9</sub>	19.54
31	C <sub>10</sub>	9.87

WSC	
CO <sub>2</sub>	6.47
H <sub>2</sub>	3.18
H <sub>2</sub>	4.18
H <sub>2</sub>	3.38

TYPE III CROSS-SECTION





PLATE	SIZE (b x d) in	Y in	A (b x d) in <sup>2</sup>	M (A x Y) in <sup>3</sup>	I <sub>y</sub> (M x Y) in <sup>4</sup>	I <sub>g</sub> (b x d <sup>3</sup> /12) in <sup>4</sup>
A	1 x 47	24.5	47	1,152	28,212	8,652
B	1 x 47	24.5	47	1,152	28,212	8,652
C	52 x 1	48.5	52	2,522	122,317	4
D	52 x 1	.5	52	26	13	4
			198	4,852	178,754	17,312
I <sub>N</sub> = 77,167 in <sup>4</sup>			N/A = 24.5"			

FORM E-050  
PRINTED IN U.S.A.

**NUSCO-MILLSTONE 2**  
**NUCLEAR POWER STATION**  
**S/G REPLACEMENT PROJECT**

18	C <sub>1</sub>	6.46
20	C <sub>1</sub>	9.97
44	C <sub>1</sub>	16.44
58	W <sub>2</sub>	12.06
80	C <sub>1</sub>	11.99
72	W <sub>2</sub>	13.86
72	C <sub>1</sub>	13.74
86	W <sub>2</sub>	15.3
86	C <sub>1</sub>	15.59
100	W <sub>2</sub>	17.2
100	C <sub>1</sub>	17.49
114	C <sub>1</sub>	19.41
26	C <sub>2</sub>	5.84
42	C <sub>2</sub>	9.87

TYPE IV CROSS SECTION



WSC	
W	0.81/0.81
CO <sub>2</sub>	6.47
H <sub>2</sub>	5.18
H <sub>2</sub>	4.16
H <sub>2</sub>	3.38

PLATE	SIZE (bxd) in	Y in	A (bxd) in <sup>2</sup>	M (AxY) in <sup>3</sup>	I <sub>y</sub> (MxY) in <sup>4</sup>	I <sub>g</sub> (bd <sup>3</sup> /12) in <sup>4</sup>
A	1 X 22.5	12.25	22.5	276	3,376	949
B	1 X 22.5	12.25	22.5	276	3,376	949
C	52 X 1	24.00	52.0	1,248	29,952	4
D	52 X 1	.50	52.0	26	13	4

149      1,826      36,717      1,906

$I_N = 36,717 + 1,906 - 1826^2 / 149 = 16,245 \text{ in}^4$

NEUTRAL AXIS =  $\frac{M}{A} = \frac{1826 \text{ in}^3}{149 \text{ in}^2} = 12.25 \text{ in}$

**NUSCO-MILLSTONE 2**  
**NUCLEAR POWER STATION**  
**S/G REPLACEMENT PROJECT**

16	C <sub>1</sub>	6.40
18	C <sub>2</sub>	8.67
24	C <sub>3</sub>	18.54
38	IC <sub>1</sub>	12.40
48	C <sub>4</sub>	11.98
72	IC <sub>2</sub>	13.88
72	C <sub>5</sub>	13.74
88	IC <sub>3</sub>	18.3
88	C <sub>6</sub>	18.50
108	IC <sub>4</sub>	17.2
108	C <sub>7</sub>	17.40
114	C <sub>8</sub>	18.41
120	C <sub>9</sub>	18.64
12	C <sub>10</sub>	8.87

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27  
28  
29  
30  
31  
32  
33  
34  
35  
36

STINGER BEAM DESIGN CONT.  
 SECTION AT 1.75' FROM & TRANSPORTER

REF: SH 12  

$$M_{1.75'} = (393.3k \times 1.75' - 56.3k) \times 1.5$$

$$= 947.9 \text{ k-FT} = 11,375.6 \text{ k-in}$$

TRY TYPE IV CROSS SECTION

$$f_b = \frac{11,375.6 \text{ in-k} \times 12.25 \text{ in}}{16,245} = 8.6 \text{ ksi OK.}$$

SECTION AT 6' FROM & TRANS, TRY TYPE II

$$M_{6'} = (393.3k \times 6' - 56.3k) \times 1.5$$

$$= 3,455.3 \text{ FT-k} = 41,463 \text{ in-k}$$

$$f_b = \frac{41,463 \times 12.25}{16,245} = 31.3 \text{ ksi OK.}$$

SECTION AT 16' FROM & TRANS.

TRY TYPE III CROSS-SECTION

$$M_{16'} = 6436.5 \text{ FT-k} = 77,238 \text{ in-k}$$

$$f_b = \frac{77,238 \times 24.5}{77,167} = 24.6 \text{ ksi OK}$$

100	MSC	
64	CO <sub>2</sub>	4.47
84	H <sub>2</sub>	4.18
28	H <sub>2</sub>	4.16
2	H <sub>2</sub>	3.28

NUSCO-MILLSTONE 2  
NUCLEAR POWER STATION  
S/G REPLACEMENT PROJECT

SP	gal/hr
18	C <sub>1</sub> 6.48
36	C <sub>2</sub> 8.87
44	C <sub>3</sub> 16.44
58	IC <sub>1</sub> 12.48
66	C <sub>4</sub> 11.96
72	IC <sub>2</sub> 13.88
72	C <sub>5</sub> 13.74
88	IC <sub>3</sub> 13.5
96	C <sub>6</sub> 15.36
108	IC <sub>4</sub> 17.2
108	C <sub>7</sub> 17.46
114	C <sub>8</sub> 18.21
28	C <sub>9</sub> 8.84
42	C <sub>10</sub> 9.87

SECTION AT 20' FROM & TRANSP.

ALL READY SIZED ON SHEETS 13-18

SECTION AT 24' FROM & TRANSP.

REF: SN 9  
TRY TYPE III CROSS-SECTION

$$M_{24'} = 281k \times 22' \times 12 = 74,184 \text{ in-k}$$

$$f_b = \frac{74,184 \times 24.5 \times 1.5}{77,167} = 35.4 \text{ ksi OK}$$

SECTION AT 32' TRY TYPE III

$$M_{32'} = 281k \times 14' \times 12 = 47,208 \text{ in-k}$$

$$f_b = \frac{47,208 \times 24.5 \times 1.5}{77,167} = 22.5 \text{ ksi}$$

TRY TYPE IV SECTION

$$f_b = \frac{47,208 \times 12.25 \times 1.5}{16,245} = 53.4 \text{ N.G.}$$

∴ USE TYPE III CROSS-SECTION

SP	gal/hr
44	CO <sub>1</sub> 8.47
24	H <sub>2</sub> 8.18
28	H <sub>1</sub> 4.18
7	H <sub>2</sub> 3.26

FLUOR DANIEL



SC-048

CALCULATIONS and SKETCHES

DATE 13 July 91

CONT. NO. B30100

BY KE600/ma/CHK'D ED

SHEET NO. 24

NUSCO-MILLSTONE 2  
NUCLEAR POWER STATION  
S/G REPLACEMENT PROJECT

NO	COND./NO.
16	C, 6.40
20	C, 9.87
44	C, 10.44
55	IC, 12.40
68	C, 11.98
72	IC, 13.88
72	C, 13.74
88	IC, 15.1
94	C, 13.50
100	IC, 17.2
100	C, 17.40
114	C, 19.41
120	C, 9.64
12	C, 9.87

SECTION AT 42' FROM  $\frac{1}{2}$  TRANSP.


$$M_{42'} = 281k \times 4' \times 1.5 \times 12in = 20,232 in-k$$

TRY TYPE IV CROSS-SECTION

$$f_b = \frac{20,232 \times 12.25}{14,245} = 15.3 ksi \text{ O.K.}$$

1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	32	33	34	35	36
---	---	---	---	---	---	---	---	---	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----

1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	32	33	34	35	36
---	---	---	---	---	---	---	---	---	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----



NUSCO-MILLSTONE 2  
 NUCLEAR POWER STATION  
 STG REPLACEMENT PROJECT

FLUOR DANIEL  
 CALCULATIONS and SKETCHES  
 DATE 1-26-91  
 CONT. NO. 230160  
 BY K. E. O. B. / D. E.  
 SHEET NO. 25

NUSCO-MILLSTONE 2

NUCLEAR POWER STATION

S/G REPLACEMENT PROJECT

18	C <sub>1</sub>	6.00
30	C <sub>2</sub>	9.87
42	C <sub>3</sub>	16.44
54	IC <sub>1</sub>	12.40
66	C <sub>4</sub>	11.95
77	IC <sub>2</sub>	13.88
89	C <sub>5</sub>	13.74
101	IC <sub>3</sub>	15.5
113	C <sub>6</sub>	13.59
125	IC <sub>4</sub>	17.2
137	C <sub>7</sub>	17.00
149	C <sub>8</sub>	16.41
161	C <sub>9</sub>	20.84
173	C <sub>10</sub>	20.87

MSC	
1	CO <sub>2</sub> 6.47
2	H <sub>2</sub> 5.18
3	H <sub>2</sub> 4.16
4	H <sub>2</sub> 3.38

1 UPPER SHEAVE NEST DESIGN

2

3 FIGURE PARTS OF LINE REQ.

4 & MAX. LEAD LINE PULL

5

6 MAX. LOAD IN THE STINGER REEving

7 AT THE & OF THE TRANSPORTER

8

9 = 397.7k SEE SH. 11 (R.)

10

11 TRY 1 1/8" φ HOIST LINE, EIPS, IWRC

12 BREAKING STRENGTH = 130.0k

13 SWL =  $\frac{130.0k * .925}{3.5}$  TERMINATION EFF. FACTOR

14

15 3.5:1 FOR MECH. SPICE

16 HOIST LINES

17

18 = 34.4k

19

20 REF MACWHYTE Pg 150

21

22  $E = \frac{(K^N - 1)}{K^S N (K - 1)}$  N = 24 No. PARTS

23

24  $\frac{2.56^{24} - 1}{1.04^{25} * 24 (1.04 - 1)}$  S = 25 No. SHEAVES

25

26  $\frac{1.04^{25} * 24 (1.04 - 1)}{2.56}$  K = 1.04 ROLLER BRGS

27

28 = 1.56 = .61

29

30

31 LEADLINE PULL =  $\frac{397.7}{24 * .61} = 27.2k < 34.4k$

32

33 O.K.

34

35

36

**NUSCO-MILLSTONE 2**  
**NUCLEAR POWER STATION**  
**57G REPLACEMENT PROJECT**

14	C <sub>1</sub>	8.40
20	C <sub>2</sub>	9.87
24	C <sub>3</sub>	18.44
28	HC <sub>1</sub>	12.40
30	C <sub>4</sub>	11.90
72	HC <sub>2</sub>	13.80
77	C <sub>5</sub>	15.74
81	HC <sub>3</sub>	15.3
84	C <sub>6</sub>	15.95
100	HC <sub>4</sub>	17.2
100	C <sub>7</sub>	17.00
114	C <sub>8</sub>	19.41
120	C <sub>9</sub>	20.4
120	C <sub>10</sub>	20.4


NSC	
W	gals/min
1	CO <sub>2</sub> 4.47
1	H <sub>2</sub> 3.18
1	N <sub>2</sub> 4.16
1	H <sub>2</sub> 3.38

FORM E-050  
 PRINTED IN U.S.A.

FIGURE SLP OF THE LANTEC HOIST AT  
 MIN. TWO BLOCK & LENGTH OF WIRE REQ.

LENGTH OF 1/8" WIRE REQUIRED:  
 REF: SH 7

CROSBY FAX DN 30" SHEAVES  
 LANTEC M#540  
 SHEAVE O.D. = 30"  
 SHEAVE TREAD  $\phi$  = 26.62"  
 PITCH  $\phi$  = 27.75"



$\pi D = 87.16''$

WIRE IN CONTACT  
 WITH THE SHEAVES

$= \frac{24 \text{ SHEAVES} \times 87.2''}{12 \times 2} = 87.2'$

WIRE BETWEEN SHEAVES

$= 10.5' \times 24 \text{ PARTS} = 252.0'$

WIRE BETWEEN DRUM &

SHEAVES = 30' (ASSUMED)

5 WRAPS ON DRUM

$5 \times \pi \times 14'' = 18.3'$

TOTAL LENGTH = 387.5' Use 450'  
 TOTAL WIRE TO SPOOL =  $183' + (10.5' - 3.33') \times 24 = 190.4'$   
 $\therefore$  SLP (FULL DRUM) = 40.6 k > 27.2 k


**NUSCO-MILLSTONE 2**  
**NUCLEAR POWER STATION**  
**STG REPLACEMENT PROJECT**

16	C <sub>1</sub>	6.40
30	C <sub>2</sub>	9.87
44	C <sub>3</sub>	18.44
58	HC <sub>1</sub>	12.40
72	C <sub>4</sub>	11.95
86	HC <sub>2</sub>	13.88
100	C <sub>5</sub>	13.74
114	HC <sub>3</sub>	15.3
128	C <sub>6</sub>	15.95
142	HC <sub>4</sub>	17.3
156	C <sub>7</sub>	18.41
170	C <sub>8</sub>	19.54
184	C <sub>9</sub>	20.7

1	CO <sub>2</sub>	5.47
1	H <sub>2</sub>	5.18
1	H <sub>2</sub>	4.18
7	H <sub>2</sub>	3.38

**UPPER SHEAVE NEST DESIGN**

NOTES: 1. ALL PLATE IS 1" A514 EXCEPT THE 1/4" A36 SHEAVE GUARD PLATE  
 2. ALL WELDS ARE FULL PEN-  
 ATRATION (FROM ONE SIDE)



SECTION AT & OF SHEAVE NEST  
 SEE NEXT SH. FOR SIDE VIEW

SCALE 1" = 10"



**NUSCO-MILLSTONE 2**  
**NUCLEAR POWER STATION**  
**S/G REPLACEMENT PROJECT**

NO	QTY	UNIT
14	C <sub>1</sub>	6.40
20	C <sub>2</sub>	9.87
44	C <sub>3</sub>	18.44
50	K <sub>2</sub>	12.40
80	C <sub>4</sub>	11.95
72	K <sub>3</sub>	13.20
72	C <sub>5</sub>	13.74
68	K <sub>4</sub>	13.5
28	C <sub>6</sub>	15.99
60	K <sub>5</sub>	17.2
60	C <sub>7</sub>	17.40
114	C <sub>8</sub>	18.41
28	C <sub>9</sub>	9.86
42	C <sub>10</sub>	9.87

SECTION AT 1.67' FROM TRANSPORTER 




PLATE	SIZE	Y	A	M	I <sub>y</sub>	I <sub>g</sub>
	(b x d) in	in	(b x d) in <sup>2</sup>	(A x Y) in <sup>3</sup>	(M x Y) in <sup>4</sup>	(b x d <sup>3</sup> /12) in <sup>4</sup>

NO	QTY	UNIT
44	C <sub>11</sub>	8.47
34	K <sub>6</sub>	5.18
28	K <sub>7</sub>	4.16
2	K <sub>8</sub>	3.26

A	45.25 x 1	28.5	45.25	1290	36,754	4
B-H	1 x 28	14.0	196.0	5,744	38,416	1,829
			241.3	4,034	75,170	1833

$I_N = 9,563 \text{ in}^4$

NEUT. AXIS =  $4,034 / 241.3 = 16.7" = C$

$M_{1.67'} = (393.3 \text{ k} \times 1.67' - 56.3 \text{ k} \cdot \text{ft}) \times 12 \text{ in} \times 1.5 = 10,809 \text{ in} \cdot \text{k}$

$f_b = 10,809 \text{ in} \cdot \text{k} \times 16.7" / 9,563 \text{ in}^4 = 18.8 \text{ ksi} \approx 2 \text{ k}$

**NUSCO-MILLSTONE 2**  
**NUCLEAR POWER STATION**  
**S/G REPLACEMENT PROJECT**

NO	QTY	UNIT
18	C <sub>1</sub>	6.00
30	C <sub>2</sub>	9.87
44	C <sub>3</sub>	10.44
50	IC <sub>1</sub>	12.40
58	C <sub>4</sub>	11.95
72	IC <sub>2</sub>	13.80
72	C <sub>5</sub>	13.74
80	IC <sub>3</sub>	15.5
86	C <sub>6</sub>	15.99
100	IC <sub>4</sub>	17.2
100	C <sub>7</sub>	17.40
114	C <sub>8</sub>	18.41
28	C <sub>9</sub>	2.84
42	C <sub>10</sub>	2.87

$M_{20''}$  FOR 2 SHEAVES SUPPORTED BY 1-1" PLATE

WORST CASE LOAD =  $53.9 \text{ k} \times 2 = 107.8 \text{ k}$

$$M_{20''} = 107.8 \text{ k} \times 20'' \times 1.5 = 3234.0 \text{ k-in}$$

$$S = \frac{bd^2}{6} = \frac{1'' \times 28.02 \text{ in}^2}{6}$$

$$= 130.7 \text{ in}^3$$

$$f_b = \frac{3234.0 \text{ k-in}}{130.7 \text{ in}^3} = 24.7 \text{ ksi} < .5F_y = 50 \text{ ksi}$$

CHECK BEARING (SHAFT)

$$t = \frac{107.8 \text{ k} \times \text{in}^2}{50 \text{ k} \times 4\frac{1}{2}'' \phi} = .48 \quad \text{USE } 1''$$

$$\text{END AREA REQ} = \frac{.66 \times 107.8 \text{ k} \times 1.5}{45 \text{ KSI}} = 2.4 \text{ in}^2$$


$$\text{AREA ACT.} = 1'' \times (12 - 4\frac{1}{2}'' \phi / 2) = 9.75 \text{ in}^2$$

CHECK BENDING IN SHAFT

$$\Sigma M_{\frac{1}{2}''} = 0$$

$$M = 53.9 \text{ k} \times \left( \frac{6\frac{3}{8}''}{2} + \frac{1''}{2} \right) - \frac{53.9 \times 6\frac{3}{8}''}{4}$$

$$= 198.9 \text{ k-in} - 86.0 \text{ k-in} = 113.0 \text{ k-in}$$



**NUSCO-MILLSTONE 2**  
**NUCLEAR POWER STATION**  
**STG REPLACEMENT PROJECT**

16	C <sub>1</sub>	6.08
20	C <sub>2</sub>	9.87
44	C <sub>3</sub>	10.44
60	NC <sub>1</sub>	12.06
68	C <sub>4</sub>	11.96
72	NC <sub>2</sub>	13.80
72	C <sub>5</sub>	13.74
88	NC <sub>3</sub>	15.53
88	C <sub>6</sub>	15.59
100	NC <sub>4</sub>	17.27
100	C <sub>7</sub>	17.08
114	C <sub>8</sub>	19.41
28	C <sub>9</sub>	9.94
42	C <sub>10</sub>	9.87

SHAFT CHECK CONT.


$$S = .098175 d^3 = .098175 \times 4.50^3 \text{ in}^3 = 8.95 \text{ in}^3$$

$$f_b = \frac{113.0 \text{ k-in} \times 1.5}{8.95 \text{ in}^3} = 19.0 \text{ KSI}$$

USE SHAFT MAT'L 4140 F<sub>y</sub> = 100 KSI

$$F_b = .5 F_y = 50 \text{ KSI} \quad \text{O.K.}$$

SHAFT LENGTH



MSC	
W	gms/cm
1	CO <sub>2</sub> 8.47
1	H <sub>2</sub> 3.18
1	N <sub>2</sub> 4.16
1	H <sub>2</sub> 3.38

NUSCO-MILLSTONE 2  
 NUCLEAR POWER STATION  
 S/G REPLACEMENT PROJECT

REV	DATE	BY	CHK'D
10	C <sub>1</sub>	6.08	
30	C <sub>2</sub>	9.87	
44	C <sub>3</sub>	10.44	
56	IC <sub>1</sub>	12.48	
68	C <sub>4</sub>	11.99	
72	IC <sub>2</sub>	13.88	
72	C <sub>5</sub>	13.74	
86	IC <sub>3</sub>	15.5	
96	C <sub>6</sub>	15.99	
100	IC <sub>4</sub>	17.2	
100	C <sub>7</sub>	17.40	
114	C <sub>8</sub>	18.41	
128	C <sub>9</sub>	19.64	
142	C <sub>10</sub>	20.87	

REV	DATE	BY	CHK'D
4	CO <sub>2</sub>	8.47	
4	H <sub>2</sub>	3.18	
6	H <sub>3</sub>	4.18	
2	H <sub>4</sub>	3.38	

IRM E-050  
 PRINTED IN U.S.A.

STINGER TIP DESIGN


SGLA STAND  
 $\phi = 82.25"$

$\frac{\phi}{2} = 41.125"$

USE 48" FOR TIP LENGTH

MAX. MOMENT

$M_{42'} = 48 \times 281.0 \text{ k} \times 1.5$   
 $= 20,232.0 \text{ k} \cdot \text{ft}$



42'  
 FROM &  
 TRANSPORTER

\*\* 2 1/4" Nut +  
 1/4" WASHER  
 = 2 1/2"

USE  $d = 18"$

$S_{REQ} = \frac{20,232.0 \text{ k} \cdot \text{ft} \times 12^2}{2 \times 0.5 F_y (A_{572 \#2})} = 963.4 \text{ in}^3$   
 $= \frac{b d^2}{6}$

$b = \frac{S_{REQ}}{d^2} = 17.8"$

USE  $b/2 = 8"$  24"

THE ACTUAL CROSS-SECTION  
 AT 42' WILL BE 18" H X 24" W  
 SOLID STEEL.

FOR WELD DESIGN BETWEEN STINGER TIP &  
 STINGER BEAM POCKET SEE SH 46




CALCULATIONS and SKETCHES

**NUSCO-MILLSTONE 2**  
**NUCLEAR POWER STATION**  
**S/G REPLACEMENT PROJECT**

NO	QTY	UNIT
16	C	6.48
20	C	9.87
41	C	18.44
58	IC	12.48
59	C	11.89
72	IC	13.88
77	C	13.74
88	IC	13.8
95	C	13.59
100	IC	17.2
100	C	17.49
114	C	19.41
38	C	2.84
42	C	9.87

NO	QTY	UNIT
H	CO	8.47
H	H.S	8.18
B	H	4.18
T	H	3.38




FORM E-050  
 PRINTED IN U.S.A.

**NUSCO-MILLSTONE 2**  
**NUCLEAR POWER STATION**  
**ST/G REPLACEMENT PROJECT**

18	C <sub>1</sub>	6.08
20	C <sub>2</sub>	9.87
44	C <sub>3</sub>	18.04
50	HC <sub>1</sub>	12.00
58	C <sub>4</sub>	11.95
72	HC <sub>2</sub>	13.00
72	C <sub>5</sub>	13.74
80	HC <sub>3</sub>	15.1
88	C <sub>6</sub>	15.90
90	HC <sub>4</sub>	17.2
100	C <sub>7</sub>	17.08
114	C <sub>8</sub>	18.41
120	C <sub>9</sub>	8.84
42	C <sub>10</sub>	9.87

FULCRUM STAND TO STINGER BEAM LUGS (2 LUGS REQ)

CHECK INTERFERENCE BETWEEN STINGER & FULCRUM STAND



48" C.C. FOR LUGS  
 SEE TYPE II SECTION SH. 19  
 SCALE 1" = 10"

LUG DESIGN

$$\text{LOAD} = 761.3 \text{ k} \times 1.5 = 1142.0 \text{ k}$$

REF SH 3

$$\text{LOAD/LUG} = 571.0 \text{ k}$$

$$t_{REQ} = \frac{571.0}{6" \phi \times 50 \text{ KSI} \times 0.5 F_Y} = 1.9" \text{ USE } 2"$$

$$\text{AREA REQ} = \frac{.66 \times 571}{45 \text{ KSI}} = 8.4 \text{ in}^2$$

$$\text{AREA ACTUAL} = 2" \times (9" - 6.125"/2) = 11.9 \text{ in}^2$$


USE FULL PENT. WELDS

SEE ADDITIONAL CALC'S ON SH 47

**NUSCO-MILLSTONE 2**  
**NUCLEAR POWER STATION**  
**S/G REPLACEMENT PROJECT**

NO	QTY	UNIT
14	C <sub>1</sub>	6.46
15	C <sub>2</sub>	9.87
16	C <sub>3</sub>	18.44
17	C <sub>4</sub>	12.48
18	C <sub>5</sub>	11.88
19	C <sub>6</sub>	13.88
20	C <sub>7</sub>	13.74
21	C <sub>8</sub>	18.3
22	C <sub>9</sub>	15.56
23	C <sub>10</sub>	17.2
24	C <sub>11</sub>	17.48
25	C <sub>12</sub>	18.41
26	C <sub>13</sub>	8.64
27	C <sub>14</sub>	9.87

LUG FOR COMPRESSION STRUTS



By LOAD COMPARISON w/ FORCES @ R<sub>2</sub>,  
 THE ABOVE LUG DIMENSIONS  
 ARE ADEQUATE FOR THE DESIGN  
 LOADS ON SH 10 & 11.

NO	QTY	UNIT
44	C <sub>15</sub>	8.47
45	H <sub>1</sub>	5.18
46	H <sub>2</sub>	4.16
47	H <sub>3</sub>	3.38

**NUSCO-MILLSTONE 2**  
**NUCLEAR POWER STATION**  
**SIG REPLACEMENT PROJECT**


16	C <sub>1</sub>	6.40
30	C <sub>2</sub>	9.87
44	C <sub>3</sub>	16.44
58	C <sub>4</sub>	12.40
72	C <sub>5</sub>	11.90
86	C <sub>6</sub>	13.86
100	C <sub>7</sub>	13.74
114	C <sub>8</sub>	13.5
128	C <sub>9</sub>	13.50
142	C <sub>10</sub>	13.2
156	C <sub>11</sub>	13.40
170	C <sub>12</sub>	13.41
184	C <sub>13</sub>	13.4
198	C <sub>14</sub>	9.87

COMPRESSION STRUT DESIGN

REF: SH 11 R<sub>2</sub> = 80.1 k COMPRESSION

LOAD/STRUT = (80.1k + 800k SGLAWT \* .05) / 2  
 (DYNAMIC LOAD)

DESIGN LOAD = 60k  
 = 60 \* 1.5 = 90k



DEAD LOAD OF PIPE = 40.5 lb/ft \* 16 = .7k

M<sub>t</sub> = PL / 4 = .7k \* 192" / 4 = 33.6 in-k

DEFLECTION = PL<sup>3</sup> / 48EI = .7k \* 192 in<sup>3</sup> / (48 \* 29000k \* 160.7 in<sup>4</sup>)

= .022 in

∴ NEGLECT BENDING & CONSIDER ONLY AXIAL STRESSES.

KL/r = 192 / 3.67 = 52.3

F<sub>A</sub> = 18.08 ksi

f<sub>A</sub> = 90.1 / 11.91 = 7.6 ksi OK

**NUSCO-MILLSTONE 2**  
**NUCLEAR POWER STATION**  
**S/G REPLACEMENT PROJECT**

NO	gals/min
16	C <sub>1</sub> 8.40
30	C <sub>2</sub> 9.87
44	C <sub>3</sub> 10.44
58	IC <sub>1</sub> 12.48
72	IC <sub>2</sub> 11.96
86	IC <sub>3</sub> 13.20
100	C <sub>4</sub> 13.74
114	IC <sub>4</sub> 16.8
128	C <sub>5</sub> 15.56
142	IC <sub>5</sub> 17.2
156	C <sub>6</sub> 17.48
170	C <sub>7</sub> 18.41
184	C <sub>8</sub> 18.64
198	C <sub>9</sub> 18.87

NO	gals/min
44	CO <sub>2</sub> 8.47
58	H <sub>2</sub> 8.18
72	H <sub>2</sub> 4.18
86	H <sub>2</sub> 3.26

CHECK 3"  $\phi$  PIN  $\phi$

$\sum M_{\downarrow} = 0$

$M = 45k \times (1" + \frac{1}{4}" + 1")$

$- 45k \times .5"$

$= 78.75 \text{ in-k}$


$S = .098175 d^3$

$= 2.65 \text{ in}^3$


$f_b = \frac{M}{S} = \frac{78.75 \text{ in-k} \times 1.5}{2.65 \text{ in}^3} = 44.6 \text{ ksi}$

$\therefore$  USE A4140 SHAFRING  $F_y = 100$

$F_b = .5 \times 100 = 50 \text{ ksi}$



DRILL  $\frac{5}{8}$ "  $\phi$  HOLES FOR  $\frac{1}{2}$ " x 8" COTTER PINS




2 REQ

**NUSCO-MILLSTONE 2**  
**NUCLEAR POWER STATION**  
**S/G REPLACEMENT PROJECT**

16	C <sub>1</sub>	6.09
20	C <sub>2</sub>	9.87
44	C <sub>3</sub>	10.44
50	HC <sub>1</sub>	12.40
58	C <sub>4</sub>	11.96
72	HC <sub>2</sub>	13.88
72	C <sub>5</sub>	13.74
80	HC <sub>3</sub>	15.5
88	C <sub>6</sub>	15.50
100	HC <sub>4</sub>	17.2
100	C <sub>7</sub>	17.40
114	C <sub>8</sub>	19.41
20	C <sub>9</sub>	6.84
42	C <sub>10</sub>	9.87

DESIGN STRUTS AS TENSION-COMPRESSION MEMBERS



$$L_{REQ} = \frac{90k \cdot 11^2}{2 \times 3.125 \text{ inch} \times 18k}$$


$$= .8 \text{ inch} \quad \text{USE 2-1" LUGS}$$

$$AREA_{REQ} = \frac{.66 \times 90k}{16.2 \text{ KSI}} = 3.67 \text{ in}^2$$

$$AREA_{ACT} = 2 \times (6 - 3.125/2) = 8.88 \text{ in}^2$$

WELD LENGTH  $l$  REQUIRED USE 5/16" WELD

$$l = \frac{90k \times 11}{9.6k \times .25 \times 8 \text{ WELDS}} = 5 \text{ inch} \quad \text{USE } \underline{\underline{10 \text{ inch}}}$$




10	MSC	
41	CO <sub>1</sub>	6.47
51	H <sub>1</sub>	3.10
58	H <sub>2</sub>	4.16
7	H <sub>3</sub>	3.26

**NUSCO-MILLSTONE 2**  
 NUCLEAR POWER STATION  
 57G REPLACEMENT PROJECT

NO	WT	GRS/HR
16	C <sub>1</sub>	6.40
20	C <sub>2</sub>	5.87
24	C <sub>3</sub>	18.44
28	C <sub>4</sub>	12.90
32	C <sub>5</sub>	11.98
36	C <sub>6</sub>	13.88
40	C <sub>7</sub>	13.74
44	C <sub>8</sub>	15.3
48	C <sub>9</sub>	15.99
52	C <sub>10</sub>	17.2
56	C <sub>11</sub>	17.99
60	C <sub>12</sub>	19.47
64	C <sub>13</sub>	8.84
68	C <sub>14</sub>	9.87

NO	WT	GRS/HR
1	CO <sub>2</sub>	6.47
1	H <sub>2</sub>	5.18
1	N <sub>2</sub>	4.18
1	H <sub>2</sub>	3.38



6"  $\phi$  PIN FOR STINGER TIP

TAIL LOAD = 281k

$F_{YPIN} = 100 \text{ ksi}$

$$S = .098175 \phi^3$$

$$= 21.2 \text{ in}^3$$

$$M_{\phi} = 140.5k \times (4" + 1.88" + 2.13") - 140.5k \times 2.13/2$$

$$= 1125.4 \text{ k-in} - 149.63 \text{ k-in}$$


$$= 975.8 \text{ k-in}$$

$$F_b = .6 \times 100 \text{ ksi} = 60 \text{ ksi}$$

$$f_b = \frac{M}{S} = \frac{975.8 \text{ k-in} \times 1.25}{21.2 \text{ in}^3}$$

$$= 57.5 \text{ ksi} < 60 \text{ ksi OK}$$

**PIN LENGTH**



**NUSCO-MILLSTONE 2**  
**NUCLEAR POWER STATION**  
**S/G REPLACEMENT PROJECT**

18	C <sub>1</sub>	8.40
20	C <sub>2</sub>	8.87
44	C <sub>3</sub>	10.44
50	H <sub>2</sub>	12.00
52	C <sub>4</sub>	11.96
72	H <sub>3</sub>	13.86
72	C <sub>5</sub>	13.74
80	H <sub>4</sub>	15.5
80	C <sub>6</sub>	15.59
88	H <sub>5</sub>	17.2
88	C <sub>7</sub>	17.49
114	C <sub>8</sub>	19.41
38	C <sub>9</sub>	8.84
42	C <sub>10</sub>	9.87

44	CO <sub>2</sub>	8.47
54	H <sub>2</sub>	8.18
58	H <sub>2</sub>	4.16
7	H <sub>2</sub>	3.38

FORM E-050  
 PRINTED IN U.S.A.

1	<b>STINGER WT TAKE-OFF</b>		
2	0' - 1.75'	1-1"X16.5"X52"	858 in <sup>3</sup>
3		SHAFT 4/8"Ø X 52" LONG = $\pi \times \left(\frac{4/8}{2}\right)^2 \times 52" =$	695 in <sup>3</sup>
4		7-1"X38"X28" PLATES	7,448 in <sup>3</sup>
5		1-1"X38"X51.25" "	1,948 in <sup>3</sup>
6		1-1"X29"X52" "	1,508 in <sup>3</sup>
7			<u>12,457 in<sup>3</sup></u>
8		WT = 12,457 in <sup>3</sup> × $\frac{500 \text{ lb/CF} \times F_T}{1728 \text{ in}^3}$ (0.289 FACTOR)	3604 lb.
9		12 - SHEAVES 200 lb × 12	2400
10			<u>6004</u>
11	1.75' - 6'	24" H x 48" W 1" R	
12		149 in <sup>2</sup> × 51" × .289	2,196 lb.
13	6 - 16'	TAPERED SECTION 1" R	
14		$\frac{(149.0 \text{ in}^2 + 198.0 \text{ in}^2) \times 120" \times .289}{2}$	6,017
15		1-1"X48"W X 29"H X .289 STIFF AT 8'	402
16			<u>6,419</u>
17	16' - 24'	48" X 48" SECTION 1 1/2" R	
18		295.5 in <sup>2</sup> × 96" × .289	8198
19		3-1 1/2" X 46" X 46" X .289 STIFF AT 16', 20', 24'	2,752
20			<u>10,950</u>
21	24' - 32'	48" X 48" SECTION 1" R	
22		198.0 in <sup>2</sup> × 96" × .289	5,494
23		1-1" X 46" X 46" X .289 STIFF AT 32'	612
24			<u>6,106</u>
25	32' - 42'	TAPERED SECTION 1" R	
26		$\frac{(198 \text{ in}^2 + 149 \text{ in}^2) \times 120" \times .289}{2}$	6,017
27		1-1" X 46" W X 34" H X .289 STIFF AT 38'	452
28		1-1" X 24" W X 48" L X .289 POCKET FOR TIP	533
29		2-1" X (34" H + 24" H) X 48" L X .289 "	805
30			<u>2</u>

**NUSCO-MILLSTONE 2**  
 NUCLEAR POWER STATION  
 SIG REPLACEMENT PROJECT

16	C <sub>1</sub>	6.46
20	C <sub>1</sub>	9.97
24	C <sub>1</sub>	13.44
28	K <sub>1</sub>	12.49
32	C <sub>1</sub>	11.56
36	K <sub>1</sub>	13.88
40	C <sub>1</sub>	13.74
44	K <sub>1</sub>	18.1
48	C <sub>1</sub>	18.59
52	K <sub>1</sub>	17.2
56	C <sub>1</sub>	17.46
60	C <sub>1</sub>	19.41
64	C <sub>1</sub>	9.84
68	C <sub>1</sub>	9.87

WISC		
44	CO <sub>2</sub>	8.47
34	H <sub>2</sub>	3.13
26	N <sub>2</sub>	4.16
17	N <sub>2</sub>	3.28

1			
2			
3		2 - 1" x 24"H x 12"W x .289 Pocker For TIP	167
4		1 - 1" x 6"H x 24"W x .289 " " "	42
5			<u>9,816</u>
6	42' - 46'	1 - 18"H x 24"W x 105"L x .289 TIP	13,109
7			
8			
9			
10			
11			<u>52,600</u>
12			lbs

LOCATE THE CG

$$\sum M_0 = 0$$

$$52,600 R_4 = .88' \times 6004k + 3.88' \times 2,196k$$

$$+ 12.7' \times 6419k + 20' \times 10,950$$

$$+ 28' \times 6,106k + 35.3' \times 7,816k$$

$$+ 42' \times 13,109k$$

$$R_4 = 24.94' \text{ FROM LEFT SIDE.}$$

CONCLUSION

LEAVE THE ESTIMATED WEIGHT OF 100k AS IS BECAUSE IT IS CONSERVATIVE IN THAT IT INCREASES THE MOMENT AT THE FULCRUM STAND & ADDS COUNTER WEIGHT TO THE TRANSPORTER.




**NUSCO-MILLSTONE 2**  
**NUCLEAR POWER STATION**  
**S/G REPLACEMENT PROJECT**

16	C <sub>1</sub>	6.40
30	C <sub>2</sub>	9.87
44	C <sub>3</sub>	16.44
58	IC <sub>1</sub>	12.40
72	C <sub>4</sub>	11.98
86	IC <sub>2</sub>	13.88
100	C <sub>5</sub>	13.74
114	IC <sub>3</sub>	15.3
128	C <sub>6</sub>	15.59
142	IC <sub>4</sub>	17.2
156	C <sub>7</sub>	17.90
170	C <sub>8</sub>	19.41
184	C <sub>9</sub>	19.84
198	C <sub>10</sub>	19.87

44	CO <sub>2</sub>	6.47
58	H <sub>2</sub> O	5.18
72	H <sub>2</sub>	4.16
86	N <sub>2</sub>	3.38

FORM E-050  
 PRINTED IN U.S.A.

STINGER BEAM  
 WELD DETAILS




SL-048

**NUSCO-MILLSTONE 2**  
**NUCLEAR POWER STATION**  
**S/G REPLACEMENT PROJECT**  
**6"φ PIN FOR FULCRUM / STINGER WGS**

NO	QTY	UNIT
18	C <sub>1</sub>	6.40
20	C <sub>2</sub>	9.87
44	C <sub>3</sub>	18.44
50	IC <sub>1</sub>	12.40
59	C <sub>4</sub>	11.95
72	IC <sub>2</sub>	13.80
72	C <sub>5</sub>	13.74
80	IC <sub>3</sub>	15.3
80	C <sub>6</sub>	15.50
80	IC <sub>4</sub>	17.2
80	C <sub>7</sub>	17.40
114	C <sub>8</sub>	18.41
20	C <sub>9</sub>	3.84
42	C <sub>10</sub>	9.87

WISC	QTY	UNIT
CO <sub>2</sub>	8.47	
H <sub>2</sub>	3.18	
N <sub>2</sub>	4.16	
O <sub>2</sub>	3.38	

JRM E-050 1  
PRINTED IN U.S.A.




STINGER LOAD (SIDE) =

$$762K(1.5) \div 2 = 571.5K$$

$$S_L = 572K$$

$$F_L = 286K/EA.$$

$$PIN S = 21.2 IN^3$$




$$M = 286K(5" + .25" + .75") - 286K(.375)$$

$$= 321.75"K$$

TRY 4140 (> 100 KSI F<sub>y</sub>)

$$F_b = .6 F_y = 60 KSI$$

$$f_b = \frac{M}{S} = \frac{321.75"K}{21.2 IN^3} = 15.18 KSI < 60 KSI \quad OK$$



NOTES:

1. USE 100 KSI MAT'L
2. TWO(2) PINS REQ'D.


**NUSCO-MILLSTONE 2**  
**NUCLEAR POWER STATION**  
**S/G REPLACEMENT PROJECT**

16	C <sub>1</sub>	6.40
20	C <sub>2</sub>	9.67
24	C <sub>3</sub>	16.44
28	IC <sub>1</sub>	12.00
32	C <sub>4</sub>	11.99
36	IC <sub>2</sub>	13.26
40	C <sub>5</sub>	13.74
44	IC <sub>3</sub>	15.5
48	C <sub>6</sub>	15.99
52	IC <sub>4</sub>	17.2
56	C <sub>7</sub>	17.99
60	IC <sub>5</sub>	19.41
64	C <sub>8</sub>	19.64
68	C <sub>9</sub>	9.67

WELD DETAILS  
STINGER TIP TO STINGER POCKET

$$R_A = \frac{286k \times 4'}{4'} = 286k$$

$$R_B = \frac{286k \times 8'}{4.0'} = 572k$$



CHECK WELD CAP @ "B"

$$\text{WELD LENGTH} = 2 \times (24" + 18") = 84"$$

$$S_w = \frac{572k \times 1.5}{84} = 10.2 \text{ K/in}$$

TRY 11/16" WELD SIZE

$$F_w = \frac{21 \times .707 \times 11}{16}$$

$$= 10.21 \text{ K/in} = 10.21$$

∴ Use 3/4" WELD

CHECK WELD CAP @ "A"

$$\text{WELD LENGTH} = 24" + 2 \times 18" = 60"$$

$$S_w = \frac{286k \times 1.5}{60} = 7.2 \text{ K/in}$$

TRY 1/2" FILLET

$$F_w = \frac{21 \times .707 \times 8}{16} = 7.42 \text{ C.K. Use } 1/2" \text{ WELD}$$

MSC		
16	C <sub>1</sub>	6.47
20	C <sub>2</sub>	9.74
24	C <sub>3</sub>	16.51
28	IC <sub>1</sub>	12.07
32	C <sub>4</sub>	12.06
36	IC <sub>2</sub>	13.34
40	C <sub>5</sub>	13.82
44	IC <sub>3</sub>	15.58
48	C <sub>6</sub>	16.07
52	IC <sub>4</sub>	17.29
56	C <sub>7</sub>	18.07
60	IC <sub>5</sub>	19.49
64	C <sub>8</sub>	19.72
68	C <sub>9</sub>	9.74

LUG DESIGN CHECK FOR COMBINED STRESS

STINGER TO FULCRUM STAND  
REF SH 12

$$M = 1.5 \times 257k \times 9''$$

$$= 3470 \text{ in-k}$$

$$A = 2'' \times 42'' = 84 \text{ in}^2$$

$$I_y = \frac{42 \times 2^3}{12} = 28 \text{ in}^4$$

$$S = \frac{2 \times 42^2}{6} = 588 \text{ in}^3$$

$$r = \sqrt{\frac{28}{84}} = .58$$

$$KL/r = 9'' / .58'' = 15.52$$

$$C_c = \sqrt{\frac{2(\pi^2 E)}{F_y}} = \sqrt{\frac{2 \times 3.14^2 \times 2900}{100}} = 76$$


$$KL/r < C_c$$

$$F_A = \left( \frac{1 - 15.52^2}{2 \times 76^2} \right) 100 = 56.2 \text{ KSI}$$

$$\frac{5 + 3 \times 15.52}{3 \times 8 \times 76} - \frac{15.52^3}{8 \times 76^3}$$

$$\frac{f_A}{F_A} + \frac{f_b}{F_e} < 1.0$$

$$\frac{718.5/84}{56.2} + \frac{3470/588}{.6 \times 100} = .25 < 1.0 \text{ O.K.}$$



16	C	8.40
18	C	9.87
20	C	11.34
22	C	12.81
24	C	14.28
26	C	15.75
28	C	17.22
30	C	18.69
32	C	20.16
34	C	21.63
36	C	23.10
38	C	24.57
40	C	26.04
42	C	27.51

16	C	8.47
18	C	9.84
20	C	11.21
22	C	12.58
24	C	13.95
26	C	15.32
28	C	16.69
30	C	18.06
32	C	19.43
34	C	20.80
36	C	22.17
38	C	23.54
40	C	24.91
42	C	26.28